



liftinstituut
SINCE 1933



EU-TYPE EXAMINATION CERTIFICATE

Issued by Liftinstituut B.V.
identification number Notified Body 0400,
commissioned by Decree no. 2018-0000125182

Certificate no. : NL09-400-1002-034-07 Revision no.: 2

Description of the product : Door locking device for swing doors

Trademark : CAN-LIFT

Type no. : CL06-M

Name and address of the manufacturer : CAN-LIFT Asansör San. Ve. TIC.LTD.ŞTİ
İnönü Mah. Balçık Köyü Yolu Üzeri
GEPOSB İçı 7. Cad. No.6 Gebze
41400 Kocaeli, Turkey

Name and address of the certificate holder : CAN-LIFT Asansör San. Ve. TIC.LTD.ŞTİ
İnönü Mah. Balçık Köyü Yolu Üzeri
GEPOSB İçı 7. Cad. No.6 Gebze
41400 Kocaeli, Turkey

Certificate issued on the following requirements : Lifts Directive 2014/33/EU

Certificate based on the following standard : Parts of: EN81-1/2:1998, EN81-20:2014, EN81-50:2014

Test laboratory : None

Date and number of the laboratory report : None

Date of EU-type examination : March 2007, April 2016, February 2021

Additional document with this certificate : Report belonging to the EU-type examination certificate no.: NL09-400-1002-034-07 Rev.2

Additional remarks : - This revision replaces certificate NL09-400-1002-034-07 Rev.1 of 26-04-2016.
- The door lock shall be used for swing doors only
Max. rated voltage 230 VAC
Max. rated current 0,5 A
Max. door gap 8 mm
See chapter 5 of the report belonging to this EU type examination certificate for additional conditions.

Conclusion : The safety component meets the requirements of the Lifts Directive 2014/33/EU taking into account any additional remarks mentioned above.

Amsterdam

Date of issue : 16-02-2021
Valid from : 26-04-2021
Valid until : 26-04-2026

ing A.J. van Ommen
International Business
Manager

Certification decision by